

---

# Type977 fitting for heat pump HP16L-WEB

## Parametric Heat Pump calculation

---

Dani Carbonell  
[dani.carbonell@spf.ch](mailto:dani.carbonell@spf.ch)

*2019/02/26 at: 11:03:15 h*

Table 1: Fitted coefficients for the heat pump.

Coefficient	Description	[kW]
$P_{Q_1}$	1 <sup>st</sup> condenser polynomial coefficient	1.7493e+01
$P_{Q_2}$	2 <sup>st</sup> condenser polynomial coefficient	2.0354e+02
$P_{Q_3}$	3 <sup>st</sup> condenser polynomial coefficient	7.4364e+00
$P_{Q_4}$	4 <sup>st</sup> condenser polynomial coefficient	-3.3252e+02
$P_{Q_5}$	5 <sup>st</sup> condenser polynomial coefficient	2.9061e+02
$P_{Q_6}$	6 <sup>st</sup> condenser polynomial coefficient	-1.4546e+02
$P_{COP_1}$	1 <sup>st</sup> COP polynomial coefficient	8.0846e+00
$P_{COP_2}$	2 <sup>st</sup> COP polynomial coefficient	7.5506e+01
$P_{COP_3}$	3 <sup>st</sup> COP polynomial coefficient	-3.4131e+01
$P_{COP_4}$	4 <sup>st</sup> COP polynomial coefficient	-2.8785e+02
$P_{COP_5}$	5 <sup>st</sup> COP polynomial coefficient	5.5102e+01
$P_{COP_6}$	6 <sup>st</sup> COP polynomial coefficient	2.5037e+01
$\dot{m}_{cond}$	3200.00 [kg/h]	
$\dot{m}_{evap}$	8000.00 [kg/h]	
$COP_{nom}$ (A0W35)	4.01	
$Q_{cond,nom}$ (A0W35)	14.84 [kW]	
$Q_{evap,nom}$ (A0W35)	11.14 [kW]	
$W_{comp,nom}$ (A0W35)	3.71 [kW]	
$RMS_{COP}$	$1.20e - 01$	
$RMS_{Q_{cond}}$	$5.51e - 01$	
$RMS_{W_{comp}}$	$7.38e - 02$	
Fit model	Average Temperature	

Table 2: Differences between experiments and fitted data for the heat pump.  $error = 100 \cdot \left| \frac{Q_{exp} - Q_{num}}{Q_{exp}} \right|$   
and  $RMS = \sqrt{\sum \frac{(Q_{exp} - Q_{num})^2}{n_p}}$  where  $n_p$  is the number of data points.

$T_{cond,out}$ °C	$T_{evap,in}$ °C	$COP$ [-]	$COP_{exp}$ [-]	error [%]	$Q_{cond}$ [kW]	$Q_{cond,exp}$ [kW]	error [%]	$W_{comp}$ [kW]	$W_{comp,exp}$ [kW]	error [%]
35.00	20.00	7.09	7.07	0.3	26.86	26.46	1.5	3.79	3.74	1.26
35.00	10.00	5.49	5.50	0.2	20.65	20.85	1.0	3.76	3.79	0.72
35.00	7.00	5.05	5.20	2.8	18.92	19.75	4.2	3.74	3.80	1.45
35.00	2.00	4.28	4.12	3.9	16.09	15.58	3.3	3.76	3.78	0.64
35.00	-7.00	3.10	3.30	6.2	11.47	12.19	5.9	3.70	3.69	0.30
35.00	-15.00	2.11	1.90	10.9	7.77	6.79	14.4	3.68	3.57	3.16
45.00	7.00	3.90	3.88	0.5	17.72	17.92	1.1	4.55	4.62	1.61
45.00	2.00	3.32	3.17	4.8	15.05	14.28	5.4	4.54	4.51	0.59
45.00	-7.00	2.44	2.44	0.1	10.73	10.65	0.7	4.40	4.37	0.63
45.00	-15.00	1.76	1.98	11.1	7.32	8.40	12.8	4.16	4.24	2.00
50.00	20.00	4.74	4.63	2.4	24.35	24.03	1.3	5.14	5.19	1.05
50.00	15.00	4.20	4.31	2.7	21.43	22.00	2.6	5.10	5.10	0.07
50.00	7.00	3.35	3.41	1.7	16.99	17.10	0.7	5.08	5.02	1.11
50.00	2.00	2.86	2.80	2.2	14.40	13.77	4.6	5.03	4.92	2.33
50.00	-7.00	2.13	2.10	1.6	10.21	10.00	2.1	4.79	4.76	0.56
55.00	20.00	3.99	4.01	0.5	23.35	23.43	0.3	5.85	5.84	0.15
55.00	7.00	2.81	2.91	3.3	16.18	16.50	1.9	5.75	5.67	1.38
55.00	-7.00	1.84	1.74	6.0	9.61	9.40	2.2	5.21	5.41	3.61
Sum				61.0			66.0			22.62
$RMS_{COP}$	1.20e - 01									
$RMS_{Q_{cond}}$	5.51e - 01									
$RMS_{W_{comp}}$	7.38e - 02									




Figure 1:  $Q_{cond}$  differences between experiments and fitted data




Figure 2:  $W_{comp}$  differences between experiments and fitted data




Figure 3:  $COP$  differences between experiments and fitted data